



# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NG-5146BR5769**

Registration Number  
Registriernummer

|   |  |
|---|--|
| <b>Field of Application</b><br><i>Anwendungsbereich</i> | products of gas supply<br><i>Produkte der Gasversorgung</i>  |
| <b>Owner of Certificate</b><br><i>Zertifikatinhaber</i> | WEICON GmbH & Co. KG<br>Königsberger Str. 255, D-48157 Münster   |
| <b>Distributor</b><br><i>Vertreiber</i>                 | WEICON GmbH & Co. KG<br>Königsberger Str. 255, D-48157 Münster   |
| <b>Product Category</b><br><i>Produktart</i>            | Greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)  |
| <b>Product description</b><br><i>Produktbezeichnung</i> | sealing material for metallic screwed joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2018 |
| <b>Model</b><br><i>Modell</i>                           | WEICONLOCK® AN 302-43  |
| <b>Test reports</b><br><i>Prüfberichte</i>              | Type testing: 14/339/5146/1 from 08.04.2015 (EBI)<br>Laboratory control test: 21-00181-KP06 from 10.12.2025 (EBI)  |
| <b>Test basis</b><br><i>Prüfgrundlagen</i>              | DIN EN 751-1 (01.05.1997)  |



70028-04-A-DE

**Date of Expiry / File No.** 18.09.2031 / 26-0372-GNV  
**Ablaufdatum / Aktenzeichen**

02.06.2026 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Josef-Wirmer-Str. 1-3  
53123 Bonn  
Tel. +49 228 9188-888  
info@dvwg-cert.com  
www.dvbw-cert.com

| Type<br><i>Typ</i>    | Technical Data<br><i>Technische Daten</i> | Remarks<br><i>Bemerkungen</i>     |
|-----------------------|---|-----------------------------------|
| WEICONLOCK® AN 302-43 | Class: H                                  | for diameters > DN 10 up to DN 50 |

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

suitable for: metallic threaded joints for use on rough threads  
not allowed in the gas installation according to DVGW-TRGI 2018