



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146DQ0773

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of gas supply
Produkte der Gasversorgung

Owner of Certificate
Zertifikatinhaber

WEICON GmbH & Co. KG
Königsberger Str. 255, D-48157 Münster

Distributor
Vertreiber

WEICON GmbH & Co. KG
Königsberger Str. 255, D-48157 Münster

Product Category
Produktart

Greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)

Product description
Produktbezeichnung

Sealing and jointing materials for screwed joints, not permissible for use in the gas installation according to DVGW-TRGI 2018

Model
Modell

WEICONLOCK® AN 305-42

Test reports
Prüfberichte

Type testing: 25-00114-AB01 from 16.07.2025 (EBI)

Test basis
Prüfgrundlagen

DIN EN 751-1 (01.05.1997)

Date of Expiry / File No.
Ablaufdatum / Aktenzeichen

16.07.2030 / 25-0556-GNE

70028-04-A-DE

28.11.2025 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. T.



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
WEICONLOCK® AN 305-42	Class: H	for diameters > DN 10 up to DN 50

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

- suitable for metallic threaded joints for use on rough threads
- not permissible for use in gas installations according to DVGW-TRGI 2018

