



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BR5770

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WEICON GmbH & Co. KG Königsberger Str. 255, D-48157 Münster
Distributor <i>Vertreiber</i>	WEICON GmbH & Co. KG Königsberger Str. 255, D-48157 Münster
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2018
Model <i>Modell</i>	WEICONLOCK® AN 306-20
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-00182-KP01 from 07.04.2021 (EBI) type testing: 12/152/5146/3 from 12.09.2012 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 18.09.2026 / 21-0371-GNV
Ablaufdatum / Aktenzeichen

30.06.2021 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
WEICONLOCK® AN 306-20	class: H	for nominal diameters > DN 10 up to DN 50

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

suitable for: metallic threaded joints for use on rough threads

not permissible for: use in the gas installation according to DVGW-TRGI 2018