

Approval Number 1910553  
Test Report: J-00338310, J-00338317 & J-00338833



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

28<sup>th</sup> July 2021

Weicon GmbH & Co. KG  
Koenigsberger Strasse 255,  
48157 Muenster,  
Germany

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**SEALANTS - SCREWED JOINTS- ANAEROBIC ADHESIVES. THESE PRODUCTS ARE TO BE APPLIED AND CURED 5520  
IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS**

'WEICONLOCK® AN 301-72 Rohr-und Flachendichtung' (white coloured) & 'WEICONLOCK® AN 301-48 Fugeverbindung' (green coloured).

Anaerobic adhesives to be applied cured in strict accordance with the manufacturer's instructions.

For use with water up to 85°C.

**APPROVAL NUMBER: 1910553**  
**APPROVAL HOLDER: WEICON GMBH & CO. KG**

The Scheme reserves the right to review approval.  
Approval 1910553 is valid between October 2019 and October 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written over a horizontal line.

**Ian Hughes**  
**WRAS Approvals Manager**