

Verification Number: SDFTSVOC20251101

Date: Nov 04,2025

VERIFICATION OF CONFORMITY

Applicant: WEICON GMBH & CO. KG

Address of Applicant: KOENIGSBERGER STRAÙE 255,48157 MUENSTER
(WESTFL.), GERMANY

PRODUCT(S)

General Description: WEICON FIRE SAFE

Model(s): 10062919

REPORT REFERENCE

Standard(s): EN 13501-1:2018 Fire classification of construction products and building elements—Part 1: Classification using data from reaction to fire tests.

Report No.: SDFTS25005941R01_EN

Date of Issue: Oct 15,2025

CONCLUSION(S)

Based upon a review of the Test Report(s), the product tested is deemed to meet the requirements of relevant standards and hence fulfils the requirements of:

Fire behaviour		Smoke production			Flaming droplets	
B	—	s	3	,	d	0

More details of the product tested, please see the report of SDFTS25005941R01_EN

This Verification is valid from Nov 04,2025 to Nov 04,2028

Authorized Signatory

(On behalf of SGS-CSTC FIRE TECHNOLOGY SERVICE DEPARTMENT)



Authorized signatory(Ada Liu)

This Verification is issued subject to the General Conditions for Inspection and Testing Services. This verification remains the property of SGS-CSTC Standard Technical Service Co., Ltd. To whom it must be returned on request. It is not permitted to use SGS logo on product or any other document. Copyright of this verification is owned by SGS and shall not be reproduced except in full, without written approval of the company.

This Verification is only valid for the product(s) supplied and tested. It is part of a full report and should be read in conjunction with it. The manufacturer is solely responsible for compliance of any products that has the same designation as the product type-tested.